


# Standard Single Wall Day Tank - PY50 thru PY150

## TANK DIMENSION REFERENCE CHART (SHOWN IN INCHES)

TANK RATED CAPACITY	A - HEIGHT (TANK)	D - DEPTH* (OVERALL)	E - MTG HOLES (CTR-TO-CTR)	F - DEPTH* (INNER TANK)	U/L VENT NPT SIZE
50 GAL.	33.50	21.00	19.50	18.00	2.00
60 GAL.	41.50	21.00	19.50	18.00	3.00
75 GAL.	46.50	21.00	19.50	18.00	3.00
100 GAL.	46.50	27.00	25.50	24.00	3.00
150 GAL.	46.50	39.00	37.50	36.00	3.00

\* Depth dimension - Front-to-Back

### PLAN VIEW (Scale = 2x)



NOTE - PUMP & MOTOR NOT SHOWN IN ORDER TO REVEAL TANK OPENINGS

REF#	DESCRIPTION OF STANDARD EQUIPMENT
1	CONTROL PANEL
2	6-1/2" X 6-1/2" INSPECTION PLATE
3	6" x 6" MOTOR MOUNTING PLATE
4	1-1/2" NPT - FUEL LEVEL GAUGE
5	FUEL INLET/OUTLET TO/FROM TANK w/DROP TUBES
6	2" x 1" NPT - ENGINE FUEL SUPPLY w/DROP TUBE
7	2" x 1" NPT - ENGINE FUEL RETURN w/DROP TUBE
8	2" NPT - TANK VENT TO ATMOSPHERE
9	1" NPT - DROP TUBES FOR ENGINE SUPPLY & RETURN
10	1" NPT - OVERFLOW TO MAIN STORAGE TANK
11	1/2" NPT - TANK DRAIN w/DROP TUBE (PLUGGED)
12	2" NPT - EXTRA CONNECTION

ADDITIONAL EQUIPMENT IF TANK IS U/L LISTED	
40	NPT CONNECTION FOR U/L EMERGENCY RELIEF VENT (See Above Chart For Size)


CONSTRUCTION NOTES	
1 -	TANK TOP, BOTTOM, & SHELL - 12 GAUGE STEEL
2 -	DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE

**STANDARD SINGLE WALL DAY TANK**  
PY50 - PY150  
PY50UL - PY150UL (U/L Listed Version)


**PRYCO, INC.**  
MECHANICSBURG, ILLINOIS

DRAWN BY: *RES* | DATE: 03/01/2008  
CHECKED BY: *DW* | REV: 03/01/2008

SHEET NO. **1 of 1** | DWG # **STD\_SW\_B**



FRONT VIEW



LEFT SIDE VIEW