


Trim Single Wall Day Tank - 10 Gallon Capacity



REF#	DESCRIPTION OF STANDARD EQUIPMENT
1	CONTROL PANEL
2	6-1/2" X 8-1/2" INSPECTION PLATE
3	REMOVABLE COVER
4	1-1/2" NPT - FUEL LEVEL GAUGE
5	FUEL INLET/OUTLET TO/FROM TANK
6	2" x 1" NPT - ENGINE FUEL SUPPLY w/DROP TUBE
7	2" x 1" NPT - ENGINE FUEL RETURN w/DROP TUBE
8	2" NPT - TANK VENT TO ATMOSPHERE
9	1" NPT - DROP TUBES for ENGINE SUPPLY & RETURN
10	1" NPT - OVERFLOW TO MAIN STORAGE TANK
ADDITIONAL EQUIPMENT IF TANK IS U/L LISTED	
40	2" NPT CONNECTION FOR U/L EMERGENCY RELIEF VENT
CONSTRUCTION NOTES	
1 - TANK TOP, BOTTOM, & SHELL - 12 GAUGE STEEL	
2 - DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE	
TRIM SINGLE WALL DAY TANK	
PY10T	
PY10TUL (U/L Listed Version)	
PRYCO, INC.	
MECHANICSBURG, ILLINOIS	
DRAWN BY: RES	DATE: 03/01/2008
CHECKED BY: DM	REV: 03/01/2008
SHEET NO. 1 of 1	DWG #: TRM_SW_A