



**DESCRIPTION OF STANDARD EQUIPMENT**

1	1 1/2" NPT FOR FUEL LEVEL GAUGE
2	3/8" NPT FUEL INLET TO TANK (PLUGGED)
3	1 1/2" X 1" NPT ENGINE FUEL SUPPLY
4	1 1/2" X 1" NPT ENGINE FUEL RETURN
5	1" NPT PIPE STEMS FOR ENGINE FUEL SUPPLY & RETURN
6	1" NPT OVERFLOW TO MAIN STORAGE TANK
7	2" NPT ATMOSPHERIC VENT FOR TANK
8	3/8" NPT TANK DRAIN
9	6 1/2" X 6 1/2" REMOVABLE INSPECTION PLATE
17	2" NPT FOR MANUAL FILL
18	1" X 1/2" NPT FOR OPTIONAL DOUBLE WALL LEAK DETECTOR
19	1" NPT RUPTURE BASIN DRAIN
22	2" NPT ATMOSPHERIC VENT FOR DOUBLE WALL
23	1 1/4" NPT FOR DOUBLE WALL INSPECTION (PLUGGED)
24	3/8" NPT DOUBLE WALL DRAIN

**ADDITIONAL EQUIPMENT FOR U/L LISTED**

20	U/L EMERGENCY RELIEF VENT FOR TANK (SEE CHART)
21	U/L EMERGENCY RELIEF VENT FOR DOUBLE WALL (SEE CHART)

**CONSTRUCTION NOTES**

TANK TOP,BOTTOM & SHELL - 12 GAUGE  
 DOUBLE WALL TOP,BOTTOM & SHELL - 12 GAUGE  
 DIMENSION SUBJECT TO CHANGE WITHOUT NOTICE

**MANUAL DAY TANK**  
 PY10 - PY25 (10-25 GALLONS)  
 WITH DOUBLE WALL & RUPTURE BASIN

**PRYCO INC.**  
 MECHANICSBURG, IL

DIMENSIONS IN INCHES	DRAWN BY: RES	SHEET NO: 1 OF 1
	CHECKED BY: R.J.W.	SCALE: 1 = 25
	DATE: 07-20-2000	DWG NUMBER:MAN-A DW RB