



DIM.	10 GAL.	15 GAL.	25 GAL.
A	20.0	26.0	31.0
B	38.0	38.0	40.0
C	36.50	36.50	38.50
D	22.0	22.0	28.0
E	20.50	20.50	26.50
F	11.0	12.0	14.0
VENT	2"	2"	2"

TOP VIEW

DESCRIPTION OF STANDARD EQUIPMENT

1	1 1/2" NPT FOR FUEL LEVEL GAUGE
2	3/8" NPT FUEL INLET TO TANK (PLUGGED)
3	1 1/2" X 1" NPT ENGINE FUEL SUPPLY
4	1 1/2" X 1" NPT ENGINE FUEL RETURN
5	1" NPT PIPE STEMS FOR ENGINE FUEL SUPPLY & RETURN
6	1" NPT OVERFLOW TO MAIN STORAGE TANK
7	2" NPT ATMOSPHERIC VENT FOR TANK
8	3/8" NPT TANK DRAIN
9	6 1/2" X 6 1/2" REMOVABLE INSPECTION PLATE
17	2" NPT FOR MANUAL FILL
18	1" X 1/2" NPT FOR OPTIONAL DOUBLE WALL LEAK DETECTOR
19	1" NPT RUPTURE BASIN DRAIN
22	2" NPT ATMOSPHERIC VENT FOR DOUBLE WALL
23	1 1/4" NPT FOR DOUBLE WALL INSPECTION (PLUGGED)
24	3/8" NPT DOUBLE WALL DRAIN

ADDITIONAL EQUIPMENT FOR U/L LISTED

- 20 U/L EMERGENCY RELIEF VENT FOR TANK (SEE CHART)
- 21 U/L EMERGENCY RELIEF VENT FOR DOUBLE WALL (SEE CHART)

CONSTRUCTION NOTES

- TANK TOP,BOTTOM & SHELL - 12 GAUGE
- DOUBLE WALL TOP,BOTTOM & SHELL - 12 GAUGE
- DIMENSION SUBJECT TO CHANGE WITHOUT NOTICE
- MANUAL DAY TANK
- PY10 - PY25 (10-25 GALLONS)
- WITH DOUBLE WALL & 200% RUPTURE BASIN



DRAWN BY: RES	SHEET NO: 1 OF 1
CHECKED BY: R.J.W.	SCALE: 1 = 25
DATE: 11-02-05	DWG.#: MAN-A DW RB 200%

