




FRONT VIEW



RIGHT SIDE VIEW




REAR VIEW



LEFT SIDE VIEW

DIM.	200 GAL.	275 GAL.	300 GAL.	400 GAL.	500 GAL.	600 GAL.	700 GAL.	800 GAL.	900 GAL.	1000 GAL.
B	24.00	27.00	28.00	34.00	42.00	42.00	48.00	52.00	56.00	58.00
C	21.00	24.00	25.00	31.00	39.00	39.00	45.00	49.00	53.00	55.00
D	54.00	66.00	66.00	72.00	72.00	80.00	82.00	86.00	90.00	96.00
E	51.00	63.00	63.00	69.00	69.00	77.00	79.00	83.00	87.00	93.00
F	48.00	60.00	60.00	66.00	66.00	74.00	76.00	80.00	84.00	90.00
VENT	4"	4"	4"	4"	4"	4"	4"	4"	6"	6"



TOP VIEW
(SCALE: 2X)

DESCRIPTION OF STANDARD EQUIPMENT

- 1 1 1/2" NPT FOR FUEL LEVEL GAUGE
- 2 3/8" NPT FUEL INLET TO TANK
- 3 2" x 1" NPT ENGINE FUEL SUPPLY W/PIPE STEM
- 4 2" x 1" NPT ENGINE FUEL RETURN W/PIPE STEM
- 5 1" NPT PIPE STEMS FOR ENGINE FUEL SUPPLY & RETURN
- 6 1" NPT OVERTFLOW TO MAIN STORAGE TANK
- 7 2" NPT VENT FOR TANK TO ATMOSPHERE
- 8 1" NPT TANK DRAIN (PLUGGED)
- 9 1 6 1/2" x 6 1/2" INSPECTION PLATE
- 15 7 GAUGE LIFTING LUG W/2" HOLE
- 17 2" NPT FOR MANUAL FILL

ADDITIONAL EQUIPMENT FOR U/L LISTED

20 NPT FOR U/L EMERGENCY RELIEF VENT(SEE CHART FOR SIZE)

CONSTRUCTION NOTES

TANK TOP,BOTTOM & SHELL - 12 GAUGE
DIMENSIONS SUBJECT TO CHANGE WITHOUUT NOTICE

MANUAL DAY TANK
PY200-PY1000 (200 - 1000 GALLONS)



DRAWN BY: RES	SEE DRAWING: NONE
CHECKED BY: DJW	SCALE: 1 = 35
DATE: 07-21-2000	DWG. NUMBER: MAN-C SW

