



FRONT VIEW




RIGHT SIDE VIEW



REAR VIEW



LEFT SIDE VIEW



ENLARGED TOP VIEW

DIM.	50 GAL.	60 GAL.	75 GAL.	100 GAL.	150 GAL.
A	33.50	41.50	46.50	46.50	46.50
B	24.00	24.00	24.00	24.00	24.00
C	23.00	23.00	23.00	23.00	23.00
D	18.00	18.00	18.00	24.00	36.00
E	17.125	17.125	17.125	23.125	35.125
G	3.00	3.00	3.00	6.00	18.00
VENT	2"	3"	3"	3"	3"

DESCRIPTION OF STANDARD EQUIPMENT	
1	1 1/2" NPT FOR FUEL LEVEL GAUGE
2	3/8" NPT INLET TO TANK (PLUGGED)
3	1" NPT ENGINE FUEL SUPPLY
4	1" NPT ENGINE FUEL RETURN
6	1" NPT OVERFLOW TO MAIN STORAGE TANK
7	2" NPT ATMOSPHERIC VENT FOR TANK
8	3/8" NPT TANK DRAIN
9	6 1/2" X 6 1/2" REMOVABLE INSPECTION PLATE
16	1" NPT ALTERNATE FUEL RETURN
17	2" NPT FOR MANUAL FILL

ADDITIONAL EQUIPMENT FOR U/L LISTED	
20	NPT FOR U/L EMERGENCY RELIEF VENT

CONSTRUCTION NOTES
 TANK TOP, BOTTOM & SHELL - 12 GAUGE
 DIMENSION SUBJECT TO CHANGE WITHOUT NOTICE

MANUAL DAY TANK
 PY50 - PY150 (50-150 GALLONS)



DIMENSIONS IN INCHES	DRAWN BY: RES	SHEET NO: 1 OF 1
	CHECKED BY: D.J.W.	SCALE: 1 = 25
	DATE: 07-20-2000	DWG NUMBER: MAN-B SW