




FRONT VIEW




RIGHT SIDE VIEW



REAR VIEW




LEFT SIDE VIEW



ENLARGED TOP VIEW

DIM.	10 GAL.	15 GAL.	25 GAL.
A	17.00	23.00	28.00
B	32.00	32.00	32.00
C	30.50	30.50	30.50
D	20.00	20.00	20.00
E	18.50	18.50	18.50
F	11.00	12.00	17.00
VENT	2"	2"	2"

DESCRIPTION OF STANDARD EQUIPMENT	
1	1 1/2" NPT FOR FUEL LEVEL GAUGE
2	3/8" NPT FUEL INLET TO TANK(PLUGGED)
3	1" NPT ENGINE FUEL SUPPLY
4	1" NPT ENGINE FUEL RETURN
5	1" NPT PIPE STEMS FOR FUEL SUPPLY & RETURN
6	1" NPT OVERFLOW TO MAIN STORAGE TANK
7	2" NPT ATMOSPHERIC VENT FOR TANK
8	1/4" NPT TANK DRAIN
9	6 1/2" X 6 1/2" REMOVABLE INSPECTION PLATE
17	2" NPT FOR MANUAL FILL
18	1/2" NPT FOR OPTIONAL RUPTURE BASIN LEAK DETECTOR
19	1" NPT RUPTURE BASIN DRAIN
ADDITIONAL EQUIPMENT FOR U/L LISTED	
20	2" NPT U/L EMERGENCY RELIEF VENT FOR TANK
CONSTRUCTION NOTES	
TANK TOP,BOTTOM & SHELL - 12 GAUGE	
RUPTURE BASIN BOTTOM & SHELL - 12 GAUGE	
DIMENSION SUBJECT TO CHANGE WITHOUT NOTICE	
MANUAL DAY TANK PY10 - PY25 (10-25 GALLONS) WITH RUPTURE BASIN	
 PRYCO INC. MECHANICSBURG, IL	
DIMENSIONS IN INCHES	DRAWN BY: RES
	CHECKED BY: D.J.W.
	DATE: 07-20-2000
	SHEET NO: 1 OF 1
	SCALE: 1 = 25
	DWG NUMBER:MAN-A SW RB