



DIM.	10 GAL.	15 GAL.	25 GAL.
A	20.00	26.00	31.00
B	40.00	40.00	40.00
C	38.50	38.50	38.50
D	28.00	28.00	28.00
E	26.50	26.50	26.50
F	8.00	10.00	15.00
VENT	2"	2"	2"

DESCRIPTION OF STANDARD EQUIPMENT

- 1 1/2" NPT FOR FUEL LEVEL GAUGE
- 2 3/8" NPT FUEL INLET TO PUMP
- 3 1 1/2" x 1" NPT ENGINE FUEL SUPPLY W/PIPE STEM
- 4 1 1/2" x 1" NPT ENGINE FUEL RETURN W/PIPE STEM
- 5 1" NPT PIPE STEMS FOR ENGINE SUPPLY & RETURN
- 6 1" NPT OVERFLOW TO MAIN STORAGE TANK
- 7 2" NPT VENT FOR TANK TO ATMOSPHERE
- 8 3/8" NPT DRAIN FOR TANK (PLUGGED)
- 9 6 1/2" X 6 1/2" INSPECTION PLATE
- 10 PUMP AND ALARM SENSORS
- 11 CONTROL PANEL
- 12 REMOVEABLE COVER
- 13 FUEL INLET THRU COVER
- 14 ELECTRICAL INLET THRU COVER
- 15 4" x 4" 7 GAUGE LIFTING LUG
- 18 NPT FOR OPTIONAL LEAK DETECTOR
- 19 1" NPT RUPTURE BASIN DRAIN (PLUGGED)
- 22 2" NPT VENT FOR DOUBLE WALL TO ATMOSPHERE
- 23 1 1/4" NPT DOUBLE WALL INSPECTION FITTING
- 24 3/8" NPT DOUBLE WALL DRAIN (PLUGGED)

ADDITIONAL EQUIPMENT FOR U/L LISTED

- 20 NPT EMERGENCY RELIEF VENT FOR TANK (SEE CHART FOR SIZE)
- 21 NPT EMERGENCY RELIEF VENT FOR DOUBLE WALL (SEE CHART)

CONSTRUCTION NOTES

TANK TOP, BOTTOM & SHELL-12 GAUGE STEEL
DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE

DAY TANK
PY10-PY25 (10 - 25 GALLONS)
WITH DOUBLE WALL & RUPTURE BASIN



**DIMENSIONS
IN INCHES**

DRAWN BY: RES	SEE DRAWING: NONE
CHECKED BY: DJW	SCALE: NONE
DATE: 07-21-2000	DWG. NUMBER: STD-A DW RB

CONSULT FACTORY FOR STANDARD PY5 (FIVE GALLON TANK CAPACITY) NOT SHOWN