



DIM.	50 GAL.	60 GAL.	75 GAL.	100 GAL.	150 GAL.
A	36.50	46.0	52.50	52.0	52.0
B	40.0	40.0	40.0	40.0	40.0
C	38.50	38.50	38.50	38.50	38.50
D	34.0	34.0	34.0	40.0	53.0
E	32.50	32.50	32.50	38.50	51.50
F	21.0	23.0	29.0	33.0	36.0
VENT	2"	3"	3"	3"	3"

**DESCRIPTION OF STANDARD EQUIPMENT**

- 1 1 1/2" NPT FOR FUEL LEVEL GAUGE
- 2 3/8" NPT FUEL INLET TO PUMP
- 3 1 1/2" X 1" NPT ENGINE FUEL SUPPLY
- 4 1 1/2" X 1" NPT ENGINE FUEL RETURN
- 5 1" NPT PIPE STEMS FOR ENGINE FUEL SUPPLY AND RETURN
- 6 1" NPT OVERFLOW TO MAIN STORAGE TANK
- 7 2" NPT ATMOSPHERIC VENT FOR TANK
- 8 3/8" NPT TANK DRAIN
- 9 6 1/2" X 6 1/2" REMOVABLE INSPECTION PLATE
- 10 PUMP AND ALARM SENSORS
- 11 LOCAL CONTROL PANEL
- 12 REMOVABLE COVER
- 13 FUEL INLET THRU REMOVABLE COVER
- 14 ELECTRICAL INLET THRU REMOVABLE COVER
- 18 1" X 1 1/2" NPT FOR OPTIONAL LEAK DETECTOR
- 19 1" NPT DRAIN FOR RUPTURE BASIN (PLUGGED)
- 22 2" NPT ATMOSPHERIC VENT FOR DOUBLE WALL
- 23 1 1/4" NPT FOR DOUBLE WALL (PLUGGED)
- 24 3/8" NPT DOUBLE WALL DRAIN

**ADDITIONAL EQUIPMENT FOR U/L LISTED**

- 20 U/L EMERGENCY RELIEF VENT FOR TANK (SEE CHART FOR SIZE)
- 21 U/L EMERGENCY RELIEF VENT FOR DOUBLE WALL (SEE CHART)

**CONSTRUCTION NOTES**

- TANK TOP, BOTTOM & SHELL - 12 GAUGE
- DOUBLE WALL TOP, BOTTOM & SHELL - 12 GAUGE
- DIMENSION SUBJECT TO CHANGE WITHOUT NOTICE

DAY TANK  
 PY50 - PY150 (50 - 150 GALLONS)  
 WITH DOUBLE WALL AND 200% RUPTURE BASIN



DIMENSIONS IN INCHES  
 DRAWN BY: RES SHEET NO: 1 OF 1  
 CHECKED BY: D.J.W. SCALE: NONE  
 DATE: 07-21-2000 DWG.#: STD-B DW RB 200%