




FRONT VIEW




RIGHT SIDE VIEW



REAR VIEW



LEFT SIDE VIEW



ENLARGED TOP VIEW

DIM.	10 GAL.	15 GAL.	25 GAL.
A	22.50	28.50	33.50
B	24.00	24.00	24.00
C	23.00	23.00	23.00
D	12.00	12.00	12.00
E	13.50	13.50	13.50
VENT	2"	2"	2"

DESCRIPTION OF STANDARD EQUIPMENT	
1	1 1/2" NPT FOR FUEL LEVEL GAUGE
2	3/8" NPT FUEL INLET TO PUMP
3	1" NPT ENGINE FUEL SUPPLY
4	1" NPT ENGINE FUEL RETURN
6	1" NPT OVERFLOW TO MAIN STORAGE TANK
7	2" NPT ATMOSPHERIC VENT FOR TANK
8	1/4" NPT TANK DRAIN
9	6 1/2" X 6 1/2" REMOVABLE INSPECTION PLATE
10	PUMP AND ALARM SENSORS
11	LOCAL CONTROL PANEL
12	REMOVABLE COVER
13	FUEL INLET THRU REMOVABLE COVER
14	ELECTRICAL INLET THRU REMOVABLE COVER
16	1" NPT ALTERNATE FUEL RETURN

ADDITIONAL EQUIPMENT FOR U/L LISTED	
20	U/L EMERGENCY RELIEF VENT FOR TANK (SEE CHART FOR SIZE)

CONSTRUCTION NOTES	
TANK TOP,BOTTOM & SHELL - 12 GAUGE	
DIMENSION SUBJECT TO CHANGE WITHOUT NOTICE	

DAY TANK
PY10 - PY25 (10 - 25 GALLONS)



DIMENSIONS IN INCHES	DRAWN BY: RES	SHEET NO: 1 OF 1
	CHECKED BY: D.J.W.	SCALE: 1 = 25
	DATE: 07-21-2000	DWG NUMBER: STD-A SW

CONSULT FACTORY FOR STANDARD PY5 (FIVE GALLON TANK CAPACITY) NOT SHOWN