



FRONT VIEW




RIGHT SIDE VIEW



REAR VIEW



LEFT SIDE VIEW



ENLARGED TOP VIEW

DIM.	50 GAL.	60 GAL.	75 GAL.	100 GAL.	150 GAL.
A	33.50	41.50	46.50	46.50	46.50
B	24.00	24.00	24.00	24.00	24.00
C	23.00	23.00	23.00	23.00	23.00
D	18.00	18.00	18.00	24.00	36.00
E	19.50	19.50	19.50	25.50	37.50
G	3.00	3.00	3.00	6.00	18.00
VENT	2"	3"	3"	3"	3"

DESCRIPTION OF STANDARD EQUIPMENT

- 1 1 1/2" NPT FOR FUEL LEVEL GAUGE
- 2 3/8" NPT FUEL INLET TO PUMP
- 3 1" NPT ENGINE FUEL SUPPLY
- 4 1" NPT ENGINE FUEL RETURN
- 6 1" NPT OVERFLOW TO MAIN STORAGE TANK
- 7 2" NPT ATMOSPHERIC VENT FOR TANK
- 8 3/8" NPT TANK DRAIN
- 9 6 1/2" X 6 1/2" REMOVABLE INSPECTION PLATE
- 10 PUMP AND ALARM SENSORS
- 11 LOCAL CONTROL PANEL
- 12 REMOVABLE COVER
- 13 FUEL INLET TO PUMP THRU REMOVABLE COVER
- 14 ELECTRICAL INLET THRU REMOVABLE COVER
- 16 1" NPT ALTERNATE FUEL RETURN

ADDITIONAL EQUIPMENT FOR U/L LISTED

20 U/L EMERGENCY RELIEF VENT FOR TANK (SEE CHART FOR SIZE)

CONSTRUCTION NOTES

TANK TOP/BOTTOM & SHELL - 12 GAUGE
 DIMENSION SUBJECT TO CHANGE WITHOUT NOTICE

DAY TANK
 PY50 - PY150 (50 - 150 GALLONS)



DIMENSIONS IN INCHES	DRAWN BY: RES	SHEET NO: 1 OF 1
	CHECKED BY: D.J.W.	SCALE: 1 = 25
	DATE: 07-21-2000	DWG NUMBER: STD-B-SW