



DIM.	50 GAL.	60 GAL.	75 GAL.	100 GAL.	150 GAL.
A	36.50	44.50	49.50	49.5	49.50
B	40.0	40.0	40.0	40.0	40.0
C	38.50	38.50	38.50	38.50	38.50
D	34.0	34.0	34.0	40.0	53.0
E	32.50	32.50	32.50	38.50	51.50
F	21.0	24.0	29.0	33.0	36.0
VENT	2"	3"	3"	3"	3"

DESCRIPTION OF STANDARD EQUIPMENT

- 1 1 1/2" NPT FOR FUEL LEVEL GAUGE
- 2 3/8" NPT FUEL INLET TO PUMP
- 3 1" NPT ENGINE FUEL SUPPLY W/PIPE STEM
- 4 1" NPT ENGINE FUEL RETURN W/PIPE STEM
- 5 1" NPT PIPE STEMS FOR ENGINE FUEL SUPPLY & RETURN
- 6 1" NPT OVERFLOW TO MAIN STORAGE TANK
- 7 2" NPT ATMOSPHERIC VENT FOR TANK
- 8 3/8" NPT TANK DRAIN
- 9 6 1/2" X 6 1/2" REMOVABLE INSPECTION PLATE
- 10 PUMP AND ALARMS SENSORS
- 11 LOCAL CONTROL PANEL
- 12 REMOVABLE COVER
- 13 FUEL INLET TO PUMP THRU REMOVABLE COVER
- 14 ELECTRICAL INLET THRU REMOVABLE COVER
- 18 1/2" NPT FOR OPTIONAL RUPTURE BASIN LEAK DETECTOR
- 19 1" NPT RUPTURE BASIN DRAIN

ADDITIONAL EQUIPMENT FOR U/L LISTED

20 U/L EMERGENCY RELIEF VENT FOR TANK (SEE CHART FOR SIZE)

CONSTRUCTION NOTES

- TANK TOP,BOTTOM & SHELL - 12 GAUGE
 - RUPTURE BASIN BOTTOM & SHELL - 12 GAUGE
 - DIMENSION SUBJECT TO CHANGE WITHOUT NOTICE
- DAY TANK
 PY50 - PY150 (50 - 150 GALLONS)
 WITH 200% RUPTURE BASIN



DRAWN BY: RES SHEET NO: 1 OF 1
 CHECKED BY: D.J.W. SCALE: 1 = 25
 DATE: 07-21-2000 DWG.#: STD-B-SW RB 200%

DIMENSIONS
 IN INCHES