



FRONT VIEW




RIGHT SIDE VIEW



REAR VIEW



LEFT SIDE VIEW



PLAN VIEW
(SCALE: 2X)

DIM.	25 GAL.	50 GAL.	60 GAL.	75 GAL.	100 GAL.
A	29.50	53.00	53.00	53.00	53.00
D	14.00	14.00	16.00	18.00	22.00
E	12.50	12.50	14.50	16.50	20.50
G	5.00	5.00	6.00	8.00	7.00
H	9.00	9.00	10.75	12.75	15.00
VENT	2"	2"	3"	3"	3"

DESCRIPTION OF STANDARD EQUIPMENT	
1	1 1/2" NPT FOR FUEL LEVEL GAUGE
2	3/8" NPT FUEL INLET TO PUMP
3	1 1/2" x 1" NPT ENGINE FUEL SUPPLY W/PIPE STEM
4	1 1/2" x 1" NPT ENGINE FUEL RETURN W/PIPE STEM
5	1" NPT PIPE STEMS FOR ENGINE SUPPLY & RETURN
6	1" NPT OVERFLOW TO MAIN STORAGE TANK
7	2" NPT VENT FOR TANK TO ATMOSPHERE
8	3/8" NPT DRAIN FOR TANK (PLUGGED)
9	6 1/2" X 6 1/2" INSPECTION PLATE
10	PUMP AND ALARM SENSORS
11	CONTROL PANEL
12	REMOVABLE COVER
13	FUEL INLET THRU COVER
14	ELECTRICAL INLET THRU COVER
15	4" x 4" 7 GAUGE LIFTING LUG
18	NPT FOR OPTIONAL LEAK DETECTOR SWITCH
22	2" NPT VENT FOR DOUBLE WALL TO ATMOSPHERE
23	1 1/4" NPT DOUBLE WALL INSPECTION FITTING
24	3/8" NPT DOUBLE WALL DRAIN (PLUGGED)

ADDITIONAL EQUIPMENT FOR U/L LISTED	
20	U/L EMERGENCY RELIEF VENT FOR TANK
21	U/L EMERGENCY RELIEF VENT FOR DOUBLE WALL

CONSTRUCTION NOTES	
TANK TOP,BOTTOM & SHELL - 12 GAUGE	
DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE	

DAY TANK
PY25T-PY100T (25 - 100 GALLONS)
TRIM WITH DOUBLE WALL



DRAWN BY: RES	SEE DRAWING: NONE
CHECKED BY: DJW	SCALE: NONE
DATE: 07-24-2000	DWG. NUMBER: TRM-B DW