


REF#	DESCRIPTION OF STANDARD EQUIPMENT
1	CONTROL PANEL
2	6-1/2" X 6-1/2" INSPECTION PLATE
3	REMOVABLE COVER
4	1-1/2" NPT - FUEL LEVEL GAUGE
5	FUEL INLET/OUTLET TO/FROM TANK
6	2" x 1" NPT - ENGINE FUEL SUPPLY w/DROP TUBE
7	2" x 1" NPT - ENGINE FUEL RETURN w/DROP TUBE
8	2" NPT - TANK VENT TO ATMOSPHERE
9	1" NPT - DROP TUBES for ENGINE SUPPLY & RETURN
10	1" NPT - OVERFLOW TO MAIN STORAGE TANK
11	1/2" NPT - TANK DRAIN (PIPED THROUGH & PLUGGED)
20	2" NPT - VENT TO ATMOSPHERE for DOUBLE WALL SECONDARY CONTAINMENT AREA
21	1-14" NPT - INSPECTION PORT for DOUBLE WALL SECONDARY CONTAINMENT AREA
22	3/8" NPT - DRAIN for DOUBLE WALL SECONDARY CONTAINMENT AREA
23	1/2" NPT - For OPTIONAL LEAK DETECTOR (NOT SUPPLIED) for DOUBLE WALL SECONDARY CONTAINMENT AREA
<b>ADDITIONAL EQUIPMENT IF TANK IS U//L LISTED</b>	
40	2" NPT CONNECTION FOR U/L EMERGENCY RELIEF VENT
	2" NPT CONNECTION FOR U/L EMERGENCY RELIEF
41	VENT for DOUBLE WALL SECONDARY CONTAINMENT AREA
<b>CONSTRUCTION NOTES</b>	
1 - TANK TOP, BOTTOM, & SHELL - 12 GAUGE STEEL	
2 - DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE	
<b>TRIM DOUBLE WALL DAY TANK</b>	
PY10TDW	
PY10TULDW (U/L Listed Version)	
 <b>PRYCO, INC.</b> MECHANICSBURG, ILLINOIS	
DRAWN BY: <i>RES</i>   DATE: 03/01/2008	
CHECKED BY: <i>D/W</i>   REV: 03/01/2008	
SHEET NO. 1 of 1   DWG #: TRM_DW_A	

Trim Double Wall Day Tank - 10 Gallon Capacity