

### OUR TANKS:

The current trend of states, cities and other jurisdictions is to require fuel systems to be configured with certain accessories. The utmost concern of Pryco engineering is for the safety and quality of its products:

- \* Most Day Tank or Subbase Tank can be **U/L Listed (Label 142)**. Refer to U/L LISTINGS on the next page for a description of all our unique U/L File Numbers.
- \* All tanks are fabricated by **Certified Welders** using **quality materials and parts**.

Below are "some" of the required accessories by state.

### STATE OF MASSACHUSETTS:

Name plate stating: Manufacturer, Tank Capacity, Gauge of Steel, Serial Number, and Date Manufactured.

### STATE OF WISCONSIN:

U/L Listed with Double Wall Construction (Day Tank and Subbase). Outdoor installations must be bullet-proof.

### STATE OF FLORIDA:

Pryco tanks are pre-approved for installation (file #EQ229). Tanks must be U/L Listed with Double Wall Construction with the following accessories:

- \* **227** - Spill Container
- \* **226**- Remote Fuel Fill Panel
- \* **509** - High Fuel Switch
- \* **509RB** - Double Wall Leak Detector
- \* **213**- Critical High Alarm
- \* **361**- Solenoid Valve, 2" Normally Open
- \* **Fill Stations EQ 762**
- \* **Day Tanks EQ 736**

**We also have seismic versions available for all types of tanks.**

### CITY OF NEW YORK:

All Tanks - 200% Rupture Basin

### CITY OF LOS ANGELES:

U/L Listed with the following accessories:

- \* **205** - Low Fuel Level Switch
- \* **209** - High Fuel Level Switch
- \* **226** - NEMA 3R Enclosure, Remotely Mounted
- \* Generator Run Circuit
- \* Pressure Relief Valve
  
- \* **302** - Manual Fill, 2" Threaded
- \* **315** - Fuel Strainer
- \* **340** - Valve, Drain-Petcock
- \* **360** - Solenoid Valve
- \* **461** - Hand Pump
- \* **464** - Pipe Stems, Engine Suction Connection (Set of Two)
  
- \* **STATE OF CALIFORNIA**- UL508

### CITY OF CHICAGO:

U/L Listed with the following accessories:

- \* **205** - Low Fuel Level Switch
- \* **213** - Critical High Switch, Pump/Motor Shut Down
- \* **385** - Rupture Basin
- \* **395** - Rupture Basin Float Switch Alarm w/ Pump/Motor Shut Down
- \* **464** - Pipe Stems, Engine Suction and Return Connections (Set of Two)
- \* **465** - U/L Listed Industrial Control Panel

Note: If HOA switch is used, the OFF position must be wired to an annunciator with a flashing yellow light on a remote or local panel.

**STATE OF COLORADO**- 75% Low in 226 Panel

**MOST GOVERNMENTAL UNITS HAVE THEIR OWN CODES. CHECK LOCAL ORDINANCES AND REGULATIONS TO ENSURE COMPLIANCE.**