



TANK DIMENSION REFERENCE CHART (SHOWN IN INCHES)

TANK RATED CAPACITY	G - WIDTH (OVER ALL)	G - WIDTH (CTR-TO-CTR MTG HOLES)	D - DEPT 1" (OVER ALL)	E - DEPT 1" (CTR-TO-CTR MTG HOLES)	F - DEPT 1" (ACTUAL TANK)	L1 VENT - NPT SIZE
200 GAL	30.00	27.00	60.00	57.00	54.00	4.00
275 GAL	33.00	30.00	72.00	69.00	66.00	4.00
300 GAL	34.00	31.00	72.00	69.00	66.00	4.00
400 GAL	40.00	37.00	78.00	75.00	72.00	4.00
500 GAL	48.00	45.00	78.00	75.00	72.00	4.00
600 GAL	48.00	45.00	86.00	82.00	80.00	4.00
700 GAL	54.00	51.00	88.00	85.00	82.00	4.00
800 GAL	58.00	55.00	92.00	89.00	86.00	4.00
900 GAL	62.00	59.00	96.00	93.00	90.00	6.00
1000 GAL	64.00	61.00	102.00	99.00	96.00	6.00

^A Depth dimension - Front-to-Back
NOTE - Both Tank & Double Wall Secondary Containment Area are vented.

REF# DESCRIPTION OF STANDARD EQUIPMENT

1	CONTROL PANEL
2	3-1/2" X 6-1/2" INSPECTION PLATE
3	3" X 6" MOTOR MOUNTING PLATE
4	1/2" NPT FUEL FLOW GAUGE
5	FUEL INLET TUBES TO/FROM TANK w/DROP TUBES
6	2" X 1/2" NPT - ENGINE FUEL SUPPLY w/DROP TUBE
7	2" X 1/2" NPT - ENGINE FUEL RETURN w/DROP TUBE
8	2" NPT - TANK VENT TO ATMOSPHERE
9	1" NPT - DROP TUBES for ENGINE SUPPLY & RETURN
10	1" NPT - OVERFLOW TO MAIN STORAGE TANK
11	1" NPT - TANK DRAIN w/DROP TUBE (PLUGGED)
12	2" NPT - EXTRA CONNECTION
20	2" NPT - VENT TO ATMOSPHERE TO DOUBLE WALL SECONDARY CONTAINMENT AREA
21	1-1/4" NPT - INSPECTION PORT TO DOUBLE WALL SECONDARY CONTAINMENT AREA
22	1" NPT - Drain to DOUBLE WALL SECONDARY CONTAINMENT AREA
23	1/2" NPT - For OPTIONAL LEAK DETECTOR (NOT SUPPLIED) for DOUBLE WALL SECONDARY CONTAINMENT AREA
ADDITIONAL EQUIPMENT IF TANK IS U/L LISTED	
40	NPT CONNECTION FOR U/L EMERGENCY RELIEF VENT (See Above Chart For Size)
41	NPT CONNECTION FOR U/L EMERGENCY RELIEF VENT for DOUBLE WALL SECONDARY CONTAINMENT AREA

CONSTRUCTION NOTES
 1 - TANK TOP, BOTTOM, & SHELL - 12 GAUGE STEEL
 2 - DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE

STANDARD DOUBLE WALL DAY TANK
 PY200DW - PY1000DW
 PY200ULDW - PY1000ULDW (U/L Listed Version)

PRYCO, INC.
 MECHANICSBURG, ILLINOIS

DRAWN BY: *RZS* | DATE: 03/01/2008
 CHECKED BY: *JW* | REV: 03/01/2008
 SHEET NO: 1 of 1 | DWG #: STD_DW_C

Standard Double Wall Day Tank - PY200DW thru PY1000DW