



PLAN VIEW
SCALE = 1.5X

TANK DIMENSION REFERENCE CHART (SHOWN IN INCHES)					
TANK RATED CAPACITY	A - HEIGHT * (TANK)	D - DEPTH ** (OVERALL)	E - MTG HOLES (CTR-TO-CTR)	F - DEPTH ** (INNER TANK)	G - HEIGHT * OF R/B
50 GAL.	32.50	34.00	32.50	24.00	2.00
60 GAL.	59.00	34.00	32.50	24.00	3.00
75 GAL.	59.00	34.00	32.50	24.00	3.00
100 GAL.	59.00	40.00	38.50	30.00	3.00
150 GAL.	59.00	52.00	50.50	42.00	3.00

* Height dimension - TANK = Inner Tank (Top to Floor); R/B = Rupture Basin (Top to Floor)
 ** Depth dimension - Front-to-Back

ACTUAL DAY TANK LIGHTEN TO EMPHASIS RUPTURE BASIN
 (Refer To Drawing #TRM_DW_B On Page 24 For Day Tank Dimensions)

MINIMUM CAPACITY OF SECONDARY CONTAINMENT (RUPTURE BASIN AREA) IS 200% CAPACITY OF THE INNER TANK

REF#	DESCRIPTION OF STANDARD EQUIPMENT
30	1" NPT - RUPTURE BASIN DRAIN
31	1/2" NPT - FOR OPTIONAL LEAK DETECTOR

CONSTRUCTION NOTES
 1 - TANK TOP, BOTTOM, & SHELL - 12 GAUGE STEEL
 2 - DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE

RUPTURE BASIN - OPTION #386
 Containment of 200% Minimum Liquid Capacity of Trim Day Tanks

PY25T - PY100T, (Standard Tanks)
 PY25TUL - PY100TUL (U/L Listed - Standard)

PRYCO, INC.
 MECHANICSBURG, ILLINOIS

DRAWN BY: *RES* | DATE: 03/01/2008
 CHECKED BY: *DJW* | REV: 03/01/2008
 SHEET NO. 1 of 1 | DWG #: RT_200_B